



Extinguisher Certificate of Inspection

Job: 5008536

Completed : 03/04/2025

Customer:

Kings Security Systems Ltd [KI0079]
4 St. Dunstons Technology Park
Bradford
West Yorkshire
BD4 7HH
Purchase.Ledger@kingsltd.co.uk

Site:

Kstl: Gloucester Crown Office [POL901598] GL1 1AD
Kings Square, Gloucester
Gloucester
Gloucestershire
GL1 1AD

Number of equipment types serviced :

Powder 1kg	Foam 2 litre AFFF	6 litre Water	4
Powder 2kg	Foam 6 litre AFFF	9 litre Water	
Powder 3kg	Foam 9 litre AFF	6 litre Water	
Powder 4kg	Foam 6 litre MultiChem	CO2 - 2kg	11
Powder 6kg	Foam 3 litre F Class	CO2 - 5kg	
Powder 9kg	Foam 6 litre F Class	LFX 6 litre	
	Fire Blanket	Hose Reel	

No of commissioned extinguishers
3

Have you signed the Log Book ?
Yes

No of Environmental Disposal ?
3

Is there a per unit service cost/ attendance fee applicable
Both unit service cost and attendance fee

Reviewed the Fire Risk Assessment
Yes

PO number if needed

Please list any further recommendations

Reasons for replaced equipment/ additional parts

Materials Used

Description	Location	Used
Fire Extinguisher Service Charge		1.00

Comments

I being the competent person responsible for the servicing of the equipment described above certify that other than non-conforming items recorded, all equipment has been serviced and inspected in accordance with BS5306 part3.

03/04/2025

Alan Edmonds

FOR EAST FIRE EXTINGUISHERS AND ALARMS UK LTD

This is to certify the service detailed in this document is satisfactory and that I/we hereby agree to pay. Terms: Subject to EAST FIRE EXTINGUISHERS AND ALARMS UK LTD standard published conditions of sale applicable to the goods or services described in this document. Copy available on request. RETENTION OF TITLE: All goods and service / repairs parts will remain the property of the East Fire until all amounts have been paid in full. The customer will remain bailee until payment.

Kings Security Systems Ltd [KI0079]

FOR CUSTOMER

You are reminded to visually inspect all your extinguishers periodically at least once a month.
When circumstances require this should be more frequent and recorded in the fire log book.